

Message

From: Hanchett, James (DPH) [/O=COMMONWEALTH OF MASSACHUSETTS/OU=MASSMAIL-01/CN=RECIPIENTS/CN=JAMES.HANCHETT]
Sent: 5/29/2012 12:53:24 PM
To: 'Ewart, Burt' [bewart@facil.umass.edu]
Subject: RE: Low Pressure Steam

Thanks,

Jim

From: Ewart, Burt [mailto:bewart@facil.umass.edu]
Sent: Tuesday, May 29, 2012 8:16 AM
To: Hanchett, James (DPH)
Subject: RE: Low Pressure Steam

Good Day, Jim!

I can't think of any reason that the low-pressure steam needs to be on for the Vivarium during the summer. All the heat there is via forced-air units, and while we use steam as an energy source for water heating, autoclaves and humidity control, all that is fed from the medium-pressure side. I'll check into it and get back to you. Thanks for the observation.

Burt

Burt Ewart

Capital Project Manager
University of Massachusetts
Facilities Planning Division
360 Campus Center Way
Amherst, MA 01003-9248

bewart@facil.umass.edu

Direct Extension: 413.577.0128
Mobile: [REDACTED]
Office Main: 413.545.1383
Fax: 413.545.3684

From: Hanchett, James (DPH) [mailto:james.hanchett@state.ma.us]
Sent: Tuesday, May 29, 2012 7:42 AM
To: Ewart, Burt
Subject: Low Pressure Steam

Hi Burt,

We are having a problem with the low pressure steam for the Vivarium Project. For the last 36 years I have been here the steam was turned off in summer months. Now it is left on. Can shut offs be installed to keep heat out of our lab and office?

Thanks,

Jim Hanchett
Amherst Drug Lab
Room N251 Morrill I
637 North Pleasant Street
Amherst, MA 01003
Phone 413-545-2607
Fax 413-545-2608
Cell [REDACTED]